



Recommended combination at mains supply 3x 400V			
HP	Motor kW	Softstarter	Braking device
>25 - 34	>18 - 25	VS II 400 - 50	VB 400 - 100 VB 400 - 200
>34 - 40	>25 - 30	VS II 400 - 60	VB 400 - 200
>40 - 50	>30 - 37	VS II 400 - 75	VB 400 - 200

This wiring proposal has been prepared with great care. Nevertheless, PETER electronic GmbH & Co. KG does not assume liability for damage resulting from mistakes possibly contained in it. We reserve the right to make changes due to technical improvements.

PETER electronic GmbH & Co. KG, Bruckäcker 9, D-92348 Berg, Tel. (09189) 4147-0, Fax (09189) 4147-47

Combination VS II with braking device VB ... - 100 ... 200

Nummer:

Verteiler:

Bearb.: A. Wein

Datum 20.07.2009

Filename: VSII-oT\_VB-100...200\_GB.skf

Geändert:

Geprüft: Ki

Blatt 1 von 1