



Recommended combination at mains supply 3x 400V			
Motor		Softstarter	Braking device
HP	kW		
20 - 25	>15 - 18	VS II 400 - 45	VB 400 - 100

This wiring proposal has been prepared with great care. Nevertheless, PETER electronic GmbH & Co. KG does not assume liability for damage resulting from mistakes possibly contained in it. We reserve the right to make changes due to technical improvements.

PETER electronic GmbH & Co. KG, Bruckäcker 9, D-92348 Berg, Tel. (09189) 4147-0, Fax (09189) 4147-47

### Combination VS II with braking device VB ... - 100

Nummer:

Verteiler:

Bearb.: A. Wein

Datum 20.07.2009

Filename: VSII\_VB-100\_GB.skf

Geändert:

Geprüft: Ki

Blatt 1 von 1