



Recommended combination at mains supply 3x 400V			
Motor		Softstarter	Braking device
HP	kW		
10	≤7,5	VS i III 525-23 C2	VB 400 - 40
15	≤ 11	VS i III 525-43 C2	VB 400 - 60

This wiring proposal has been prepared with great care. Nevertheless, PETER electronic GmbH & Co. KG does not assume liability for damage resulting from mistakes possibly contained in it. We reserve the right to make changes due to technical improvements.

PETER electronic GmbH & Co. KG, Bruckäcker 9, D-92348 Berg, Tel. (09189) 4147-0, Fax (09189) 4147-47

Combination VS i III ... C2 with braking device VB ... - 40 ... 60

Nummer:

Verteiler:

Bearb.: A. Wein

Datum 25.03.2010

Filename: VSIII-C2_VB-40...60_GB.skf

Geändert:

Geprüft: Ki

Blatt 1 von 1