



- Notes:
1. Forward and reverse contactors (K1M/K2M) must be mechanically interlocked.
 2. Forward and reverse contactors (K1M/K2M) must AC3 rated for the motor full load current.

- Legend:
- F1 Control supply fuses
 - K1A Forward run relay
 - K2A Reverse run relay
 - K3A Start relay
 - K1M Line contactor (forward run)
 - K2M Line contactor (reverse run)
 - K1T Forward run delay off timer
 - K2T Reverse run delay off timer
 - S1 Forward run signal
 - S2 Reverse run signal
 - S3 Reset pushbutton

This wiring proposal has been prepared with great care. Nevertheless, PETER electronic GmbH & Co. KG does not assume liability for damage resulting from mistakes possibly contained in it. We reserve the right to make changes due to technical improvements.

PETER electronic GmbH & Co. KG, Bruckäcker 9, D-92348 Berg, Tel. (09189) 4147-0, Fax (09189) 4147-47		
VS i III ... , reversing circuit		Nummer:
		Verteiler:
Bearb.: A. Wein	Datum 17.11.2010	Filename: VSIII_Wendeschtaltung.skf
Geändert:	Geprüft: Ki	Blatt 1 von 1